



October 18, 2016

Technical Bulletin TB-2016-07

I. Approved Product – Owens Corning:

ARCA Warranty Ltd. is pleased to confirm that the following roofing products have been reviewed and approved, and will be eligible for inclusion in the ARCA five (5) Warranty program for jobs bid after November 28th, 2016.

STEEP SLOPE CHANGES:

Owens Corning Oakridge ® shingles

This change will be referenced in the following sections of the ARCA Roofing Application Standards Manual:

- SS 2.8.2.1.d.
- ARCA ACCEPTED ASPHALT SHINGLES



II. Approved Products – CGC

ARCA Warranty Ltd. is pleased to confirm that the following roofing products have been reviewed and approved, and will be eligible for inclusion in the ARCA five (5), ten (10) and fifteen (15) Year Warranty program for jobs bid after November 28th, 2016.

AUXILIARY LEVELING SURFACE:

- CGC Securock ® 9.5mm (3/8”) Gypsum Fiber Roof Board

This change will be referenced in the following sections of the ARCA Roofing Application Standards Manual:

- BUR 3.2.1.2.
- MB 3.2.1.2.
- EPDM 3.2.2.4.1.
- TP 3.2.2.4.1.

GYPSUM FIBER ROOF BOARD COVER BOARD

- CGC Securock ® 9.5mm (3/8”) Gypsum Fiber Roof Board

This change will be referenced in the following sections of the ARCA Roofing Application Standards Manual:

- MB 5.8.4.
- EPDM 5.4.3.
- TP 5.4.3.
- ARCA ACCEPTED ROOFING INSULATION & OVERLAYS



III. Approved Products – Soprema:

ARCA Warranty Ltd. is pleased to confirm that the following roofing products have been reviewed and approved, and will be eligible for inclusion in the ARCA five (5), ten (10) and fifteen (15) Year Warranty program for jobs bid after November 28th, 2016.

INSULATION CHANGES:

- Sopra-ISO (manufactured in Drummondville QC)
- Sopra-ISO Plus

This change will be referenced in the following sections of the ARCA Roofing Application Standards Manual:

- BUR 5.6.1.2.a.
- MB 5.8.1.2.a.
- EPDM 5.4.1.2.a.
- TP 5.4.1.2.a.
- ARCA ACCEPTED ROOFING INSULATION & OVERLAYS

COMPOSITE COVER BOARD:

- Soprabase HD
- Xpress Board HD

This change will be referenced in the following sections of the ARCA Roofing Application Standards Manual:

- MB 6.6
- MB 7.5.2.
- ARCA ACCEPTED ROOFING INSULATION & OVERLAYS

ACCEPTED SHEET MEMBRANE FLASHING MATERIALS:

- Sopraflash Stick 20
- Sopraflash Stick 40
- Sopralene Stick HR 20
- Sopralene Stick HR 40
- Sopraply 520 Base

This change will be referenced in the following sections of the ARCA Roofing Application Standards Manual:

- MB 7.4.

ACCEPTED ADHESIVE:

- Duotack 365

This change will be referenced in the following sections of the ARCA Roofing Application Standards Manual:

- MB 5.7.2.1.a.
- MB 5.9.2.1.a.
- ARCA ACCEPTED ROOFING INSULATION & OVERLAYS



IV. Auxiliary Leveling Surface

The following standards have been reviewed and approved by ARCA Warranty Ltd., and will be in effect for jobs bid after November 28, 2016.

Standard being replaced:

ARCA accepted auxiliary leveling surfaces may be comprised of a minimum 12.7mm (1/2") thick layer of gypsum board, plywood, O.S.B., perlite or wood fiberboard roof insulation.

New Standard:

ARCA accepted auxiliary leveling surfaces may be comprised of a minimum 9.5mm (3/8") thick Fibre Reinforced Gypsum Panel (ASTM 1278), 12.7mm (1/2") thick Glass Mat Gypsum Substrate (ASTM 1177), 12.7mm (1/2") thick plywood, or 12.7mm (1/2") thick O.S.B. when not used as a thermal barrier.

This change will be referenced in the following sections of the ARCA Roofing Application Standards Manual;

- BUR 3.2.1.2.
- MB 3.2.1.2.
- EPDM 3.2.2.4.1.
- TP 3.2.2.4.1.